

Series 55-200 Armored Flowmeter With Magnetic Indicator with

Varea-Com[™] Electronic Transmitter FM Approved



A cleanwater Company





TUBE SIZE	Α	В	С	D	E	н	к	L	м	N	Р
½" (13mm)	2- ¹ / ₁₅ " (68mm)	2-1/8 (54mm)	5 " (127mm)	1- ¹³ /16" (46mm)	7-½" (191mm)	4- ³ / ₁₆ " (106mm)	5-1/8" (149mm)	2-1/4" (57mm)	3-¾" (95mm)	½" NPT	_
1"	3-½6"	2-½"	5 "	2"	8- ¹⁵ /16"	4-½"	5-1/8"	2-1/4"	4-5/16"	1" NPT	5/6 "
(25mm)	(78mm)	(73mm)	(127mm)	(51mm)	(227mm)	(114mm)	(149mm)	(57mm)	(110mm)		(8mm)
1-½"	3-%6"	4-1/8"	5 "	2-¾"	11-%"	5 "	5-1/8"	2-1/4"	4-%6"	1-½" NPT	1"
(38mm)	(90mm)	(105mm)	(127mm)	(70mm)	(295mm)	(127mm)	(149mm)	(57mm)	(116mm)		(25mm)
2"	4"	4-¾"	5 "	3"	12-1/8"	5-½6"	5-1/8"	2-1/4"	5"	2" NPT	1-¾"
(51mm)	(102mm)	(121mm)	(127mm)	(76mm)	(327mm)	(138mm)	(149mm)	(57mm)	(127mm)		(35mm)

NOTES:

- ACCESSORY ITEM FURNISHED ONLY IF SPECIFICALLY LISTED IN QUOTATION AND AS CHECKED ON THIS DRAWING.
- ▲ FM APPROVED EXPLOSION PROOF FOR CLASS I, DIV I, GROUPS A, B, C, & D HAZARDOUS LOCATION AND DUST IGNITION PROOF FOR CLASS II, DIV I, GROUPS E, F, & G HAZARDOUS LOCATION; SUITABLE FOR CLASS III, DIV I WITH APPROVED BARRIER.

UGSI Chemical Feed, Inc.

a Cleanwater1 company

Vineland, NJ 08360 856.896.2160 phone

info@cleanwater1.com www.cleanwater1.com

Dimensions CF.550.200.106.CN.0723